CANLYTE 3015 Louis Amos Lachine, Qc. H8T 1C4

Tel.: (514) 636-0670 - Fax.: (514) 636-0460

www.canlyte.com

## INSTRUCTION SHEET

**IS9220** 

04-06/Rev-00

## INSTALLATION INSTRUCTIONS FOR T-SWIVEL PROJECTOR FOR LYTESPAN TRACK

WARNING: For use with Lytespan track system only.


CAUTION: Use only the lamp type and the Maximum wattage as marked on the trim.


ATTENTION: Read and understand these instructions before installing fixture. To prevent electrical shock, turn off electricity at fuse box before proceeding.

Retain these instructions for maintenance reference.

## A. SINGLE CIRCUIT:

- 1. Position *lever* 90° with *track*. (Fig.1)
- 2. Align <u>bead</u> on <u>track</u> with <u>groove</u> in <u>T-swivel</u>. (Fig.1) Warning: Align the <u>bead</u> with the <u>groove</u> to provide the polarity.
- Insert the <u>adapter</u> into <u>track</u> and turn <u>lever</u> 90°clockwise. (Fig.2)
  - Warning: Make sure the lever is turned at 90° in order to have proper contact.
- To remove or shift projector on <u>track</u>, turn <u>lever</u> 90° counterclockwise. (Fig.1 and 2)





## B. DOUBLECIRCUIT:

Note: Use the spacer provided (must be used at all times).

CIRCUIT 1: (Low brass contact)

 Slide the <u>spacer</u> into the <u>brass contact</u> until it cliks into place. (Fig.3)

CIRCUIT 2: (High brass contact)

- 1a. Raise the brass contact until it cliks into position. (Fig.4)
- 1b. Slide the *spacer* under the *brass contact*. (Fig.4 and 5)
- 2. Repeat previous steps (A) single circuit: 1 to 4.

