

CERTIFICATE

Issued to:
Applicant:
Signify Netherlands B.V.
High Tech Campus 48
5656 AE Eindhoven, Netherlands

Licensee:
Signify Netherlands B.V.
High Tech Campus 48
5656 AE Eindhoven, Netherlands

Product : Lighting Controller
Trade name(s) : PHILIPS or SIGNIFY
Type(s)/model(s) : EasyAir Occu-DL MP 4M sensor MC and MPS2100/05 OCC-DL IA WH 4M

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN 61347-2-11:2001, EN 61347-2-11:2001/A1:2019, EN 61347-1:2015 and EN 61347-1:2015/A1:2021
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 947556


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 25 February 2025 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 31-154509

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



Kreny Lin
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Lighting Controller
Trade name(s)	: PHILIPS or SIGNIFY
Type(s)/model(s)	: EasyAir Occu-DL MP 4M sensor MC and MPS2100/05 OCC-DL IA WH 4M
Input voltage	: 220-240 Vac
Frequency	: 50/60 Hz
Input current	: 10 mA
Input power	: 250 mW
Max. case temperature (tc)	: 55 °C
Ambient temperature (ta)	: 0...+50°C
Description	: independent

TESTS**Test requirements**

EN 61347-2-11:2001
EN 61347-2-11:2001/A1:2019
EN 61347-1:2015
EN 61347-1:2015/A1:2021

Test result

The test results are documented in DEKRA test file 621021800.

Additional information

The control circuits with PIR & light sensor parts and Zigbee / BLE transceiver parts is evaluated as SELV circuit.

The tests were performed by the manufacturer under the conditions of the agreement concerning the manufacturer's right to conduct type tests for the ENEC certification system under supervision of DEKRA (CTF Stage 3).

The list of components is laid down in test report 6210218.50(A-B).

Conclusion

The examination has confirmed that all requirements were met.

Factory locations

The factory locations are registered with the numbers 674666 and 305810.

Trade name(s) : PHILIPS Stands for **PHILIPS**