

Philips EasySense SNS210 MC Step-by-Step Instruction

How to add EasySense



Version 1.0

#### Before you begin:

- 1. Philips MasterConnect field app is installed on the smartphone
- 2. Target LED Fixture must be powered
- 3. The SNS210 MC red LED indicator should be fully lit
- 4. Compatible wireless light switch
- 5. Optional flashlight for commissioning











- 1. Launch MasterConnect app
- 2. Select the group you want to configure.



- 1. Launch MasterConnect app
- 2. Select the group you want to configure.
- 3. The Lights tab will be selected by default. Select the 🖶 icon to add a light.



- 1. Launch MasterConnect app
- 2. Select the group you want to configure.
- 3. The Lights tab will be selected by default. Select the 🖶 icon to add a light.
- 4. Selects lights to initiate the scanning process



- 1. Launch MasterConnect app
- 2. Select the group you want to configure.
- 3. The Lights tab will be selected by default. Select the 🖶 icon to add a light.
- 4. Selects lights to initiate the scanning process
- 5. Ready for commissioning





**NI**17

# B1. Flashlight commissioning



# B1. Flashlight Commissioning Point a flashlight at the EasySense SNS210 MC





- Point a flashlight at the EasySense SNS210 MC
- 2. An audible tone and vibration will be generated when a flashlight is detected by the sensor





- 1. Point a flashlight at the EasySense SNS210 MC
- 2. An audible tone and vibration will be generated when a flashlight is detected by the sensor
- 3. Once the target light is successfully added an additional audible tone will be generated and the light will dim down



- 1. Point a flashlight at the EasySense SNS210 MC
- 2. An audible tone and vibration will be generated when a flashlight is detected by the sensor
- 3. Once the target light is successfully added an additional audible tone will be generated and the light will dim down
- 4. All the added lights will appear on the list





- 1. Point a flashlight at the EasySense SNS210 MC
- 2. An audible tone and vibration will be generated when a flashlight is detected by the sensor
- 3. Once the target light is successfully added an additional audible tone will be generated and the light will dim down
- 4. All the added lights will appear on the list
- 5. Press Finish Adding when done











1. Select the Discovered botton



- 1. Select the Discovered button
- 2. Press the ADD button for all the lights to be added



- 1. Select the Discovered button
- 2. Press the ADD button for all the lights to be added
- 3. As each light is added the Added counter will be incremented



- 1. Select Discovered
- 2. Press the ADD button for all the lights to be added
- 3. As each light is added the Added counter will be incremented
- 4. Walk around to scan for more lights or press FINISH ADDING



- 1. Select the Discovered button
- 2. Press the ADD button for all the lights to be added
- 3. As each light is added the Added counter will be incremented
- 4. Walk around to scan for more lights or press FINISH ADDING button
- 5. Press the < icon to go to the previous menu or the 🖶 icon to add more lights







#### 1. Select the 主 icon

		PHILI
11:23 AM	35% •••	
Rosemont office 4 DEVICE(S)		~
Lights	Switches	
✓ Group devices 4 DEVICE(S)		
SNS210_70B8	:	
SNS210_B044	:	
SNS210_E868	:	
\$210_0C30 +		

- 1. Select the 🔅 icon
- 2. Select Enable Test Mode

	PHILIP
11:23 AM 35% - +	(
Rosemont office 4 DEVICE(S)	
Lights Switches	
Group devices 4 DEVICE(S)	
Group info	
Enable Test Mode	
Create a zone	
Remove all switches	
Delete group	
Cancel	

- 1. Select the 🔅 icon
- 2. Select Enable Test Mode
- 3. Test by turning lights on/off with the toggle switch



- 1. Press the : icon to start
- 2. Select Enable Test Mode
- 3. Test all lights by turning them on/off with the toggle switch or changing the dimming level with the blue bar
- 4. Press the < icon to exit





If you have questions or need further assistance please visit us at

#### https://www.signify.com/en-us/get-in-touch or www.Philips.com/EasySense

