



Strip 1 x 9290026952 3000K

1 x 750 lm


Polar intensity diagram



Quantity estimation diagram



UGR diagram



Light output ratio 1.00
Service upward 0.00
Service downward 1.00

CIE flux code 46 79 96 100 100

UGRcen (4Hx8H, 0.25H) 23

Utilisation factor table

Room Index k	Reflectances (%) for ceiling, walls and working plane (CIE)											
	0.80	0.80	0.70	0.70	0.70	0.70	0.50	0.50	0.30	0.30	0.00	0.00
0.60	0.80	0.80	0.50	0.50	0.30	0.10	0.30	0.10	0.10	0.10	0.00	0.00
0.80	0.80	0.80	0.50	0.50	0.30	0.10	0.30	0.10	0.10	0.10	0.00	0.00
1.00	0.80	0.80	0.50	0.50	0.30	0.10	0.30	0.10	0.10	0.10	0.00	0.00
1.25	0.80	0.80	0.50	0.50	0.30	0.10	0.30	0.10	0.10	0.10	0.00	0.00
1.50	0.80	0.80	0.50	0.50	0.30	0.10	0.30	0.10	0.10	0.10	0.00	0.00
2.00	0.80	0.80	0.50	0.50	0.30	0.10	0.30	0.10	0.10	0.10	0.00	0.00
2.50	0.80	0.80	0.50	0.50	0.30	0.10	0.30	0.10	0.10	0.10	0.00	0.00
3.00	0.80	0.80	0.50	0.50	0.30	0.10	0.30	0.10	0.10	0.10	0.00	0.00
4.00	0.80	0.80	0.50	0.50	0.30	0.10	0.30	0.10	0.10	0.10	0.00	0.00
5.00	0.80	0.80	0.50	0.50	0.30	0.10	0.30	0.10	0.10	0.10	0.00	0.00

Ceiling mounted

Luminance Table

Plane Cone	0.0	15.0	30.0	45.0	60.0	75.0	90.0
45.0	6224	6029	5859	5719	5617	5555	5534
50.0	6179	5950	5751	5591	5474	5403	5380
55.0	6075	5807	5578	5395	5263	5183	5157
60.0	5954	5638	5373	5164	5015	4925	4896
65.0	5708	5338	5034	4799	4634	4535	4503
70.0	5372	4934	4586	4324	4142	4036	4001
75.0	4793	4277	3888	3606	3416	3306	3271
80.0	4001	3381	2955	2666	2481	2377	2344
85.0	2790	2038	1629	1390	1249	1175	1152
90.0	118750	730	379	268	219	197	190

(cd/m²)

2021-08-11